



MEMORANDUM

TO: Mr. Mark W. Pickering, P.E.

FROM: Gary L. Shuman

RE: Beach High School Baseball Fields - RFI Responses

DATE: January 20, 2016

CC: Steve Wohlfeil

Date: 1-13-2016

1. The Typical retaining Wall shown on C7.4 shall be a “Modular Concrete Retaining Wall” conforming to ASTM C1372, 3,000 PSI minimum compressive strength at 28 days. Retaining wall shall be Standard Unit Series (using a 1” setback) as manufactured by “Keystone Retaining Wall Systems” or approved equivalent and installed as recommended and specified by the manufacturer. No rebar is required unless specified by the manufacturer for the specific conditions encountered.
2. Block & Paint colors shall be coordinated with the owner as indicated on Drawing C7.0. Concrete block and mortar joints shall be grey in color unless directed otherwise by the owner.

Date: 1-14-2016

1. All fencing shall be “Master Halco” (or approved equivalent) black polyolefin coated chain link fence and gates system. Install per manufacturers specifications and recommendations. Outfield fencing shall have a fence crown-yellow poly tube cap installed in conformance with the manufacturers specifications.