

HVAC Platform Removal & Installation at District's Central Office

Bid: C16-31

Addendum #1

Closing Date: 04/19/2016 at 11:00 am

The information contained in this document shall become an official part of the original document and shall be acknowledged as noted on the Certification Form (SCCPSS Bid Form 1) of solicitation document in the space provided. Failure to acknowledge receipt of an addendum may result in a status of non-responsive. Firms are encouraged to review the contents of this document and to respond accordingly.

Addendum No. 1 is issued to provide answers to questions submitted, provide a copy of the pre-bid register, and provide a Revised drawing S1-1.

Question:	District's Response:
1. There are areas where the new structural steel will fit into the existing masonry wall. Does the contractor need to infill the opening in the wall with masonry after the new steel is installed? The existing steel has an opening left in the masonry.	No infill required.
2. Will the project require a building permit with the City of Savannah? If so, will the contractor be responsible for paying for the permit or will the City of Savannah waive the fee for the SCCPSS?	Yes. The contractor will be responsible for paying the permit.
3. Since there are various trades, masonry, electrical HVAC, structural steel, etc. will the project require the contractor to have a general contractors license?	Yes.
4. Some locations where the existing steel is located, the wood window sills have rotten wood. Will the contractor be required to repair and paint the wood sills?	Yes.
5. Can the work be performed during business hours such as Monday-Friday 7:00 am – 5:00?	Yes.

*****ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED*****

End of Addendum #1 to Bid C16-31 HVAC Platform Removal & Installation at District's Central Office

C16-31
 HVAC Platform Removal and Installation at District's Central Office
 PRE-BID REGISTER
 March 31, 2016 @ 10:00 AM

NAME	COMPANY	EMAIL	PHONE #	FAX #
Langdon Cooper	SCCPSS	Langdon.Cooper@sccpss.com	895-5230	
Eddie Dean	Southeastern A-C	edean@southeasternac.com	964.0220	966-2340
Arnold Jackson	SCCPSS		556 3	(912)
BRYAN RAY	K.R.L.	BRYAN@KENTRANCONSTRUCTION.COM	352.4676	352.4677
Jean Carter	SCCPSS	jean.carter@sccpss.com	912 395-5573	912 201-7648
Hunter Bussy	Bussy Engineering	HBussy@BussyEngineering.com	912 899 8255	912 898.1882