

Transportation Shop Roll Up Door Replacement

Number: BID C19-12

Addendum # 1

Date Posted: 11/08/18

Closing Date: 11/15/18 11:00 A.M.

The information contained in this document shall become an official part of the original document and shall be acknowledged as noted on the Certification Form (Form 1) of solicitation document and the Bid Form (Form 10) in the space provided. Failure to acknowledge receipt of an addendum may result in a status of non-responsive. Firms are encouraged to review the contents of this document and to respond accordingly.

Addendum No. 1 is being issued to provide answers to questions submitted.

Questions	Answer
<p>1. Per 2.2.2.a the curtain is called out to be 26 gauge with a two coat baked on polyester. In 2.2.5 and 2.2.6 the guides and head plates are called out to be powder coated.</p> <p>Why are we using such an expensive finish on the guides and head plates on such a light duty door?</p> <p>Why is the hood 24 gauge heavier than the curtain? The hood is not powder coated to match?</p>	<p>The finish for the guides and head plates shall be the manufacturer's standard finish for that specific item. Delete the powder coat for the guides and head plates.</p> <p>The hood finish shall be the manufacturer's standard hood finish, which is to match the door (painted, white).</p> <p>The new exterior garage doors shall be painted to match the existing color. The first coat of the garage door shall be painted with a metal primer and second coat painted with a semi-gloss latex enamel paint. The top color of the roll up doors should be untinted extra white and the bottom color formula should be (shamrock green).</p>

*****ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED*****

End of Addendum #1 to Bid C19-12