

Cooling Tower Replacement at Johnson High School
BID C16-41
Addendum # 1
Closing Date: 04/12/2016 at 2:00 pm

The information contained in this document shall become an official part of the original document and shall be acknowledged as noted on the Certification Form (SCCPSS Bid Form 1) of solicitation document in the space provided. Failure to acknowledge receipt of an addendum may result in a status of non-responsive. Firms are encouraged to review the contents of this document and to respond accordingly.

Addendum No. 1 is being issued to modify the specifications for Motor on page 18 of the solicitation to read as follows:

Motor: Motors shall be totally enclosed, specially insulated for cooling tower duty. Speed and electrical characteristics shall be 1800 (or 1800/900) RPM, single winding, 3 phase, 60 hertz, 480 volt. The motor shall be provided by the vendor to accommodate frequent speed changes that are inherent with VFD applications.

A copy of the pre-bid register is provided with Addendum #1.

*****ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED*****

End of Addendum #1 to Bid C16-41 Cooling Tower Replacement at Johnson High School

