

Windsor Forest High School ADA Renovations Project
Number: BID C17-18
Addendum # 2

The information contained in this document shall become an official part of the original document and shall be acknowledged as noted on the Certification Form (Form 1) of solicitation document and the Bid Form (Form 10) in the space provided. Failure to acknowledge receipt of an addendum may result in a status of non-responsive. Firms are encouraged to review the contents of this document and to respond accordingly.

Addendum No. 2 is being issued to provide the following change:

Preparation of existing substrates by sandblasting not required. All references to sandblasting existing walls to remove epoxy finish (reference A1.0/A102, A1.0/A103) shall be deleted and replaced with the following:

“REMOVE EXISTING EPOXY PAINT FINISH, APPURTENACES AND MISCELLANEOUS FASTENERS FROM MASONRY WALLS SCHEDULED TO REMAIN. PREPARE WALLS TO RECEIVE NEW SCHEDULED FINISHES.”

*****ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED*****

End of Addendum #2 to Bid C17-18 Windsor Forest High School ADA Renovations Project