

Data Cabling for New May Howard Elementary School

Number: RFP 16-54

Posting Date: 1/26/2016

Addendum # 1

Closing Date: 02/10/16 @ 11:00 A.M.

The information contained in this document shall become an official part of the original document and shall be acknowledged as noted on the Certification Form of the solicitation document. Failure to acknowledge receipt of an addendum may result in status of non-responsive. Firms are encouraged to review the contents of this document and to respond accordingly.

Addendum No. 1 is issued to respond to questions submitted in response to this solicitation and to provide clarification.

Question:	Answer:
1. Is the physical equipment provided by SCCPSS?	Yes.
2. Can you specify the gateway locations?	Please refer to the EAC drawings provided with this addendum. The plan calls for cabling ten (10) gateways and two (2) IP10s.
3. How do you prefer for testing and certification documentation to be provided?	The documentation can be provided on a CD.
4. Who is responsible for caulking any penetrations?	The data cabling contractor is responsible for caulking all penetrations once the cabling has been completed.
5. Please provide information on the mounting of the AP wireless connections.	You will only mount the AP in the areas that SCCPSS identifies, the current total for New May Howard is sixty-four (64). These devices are mounted mostly in the ceiling grid.
6. Please confirm the type of faceplates required. We have used stainless steel in the past. Per the specifications are we to use 6 Port, Plastic Faceplates?	Stainless Steel.
7. Please provide the RFP for all (5) schools in a word document for bidding purposes.	The bid documents are provided as PDFs on the District's website. No Word document will be provided.
8. Page 17 – Bid Form indicates. #3 Mount and Test cameras shown on drawings. Is the cabling for the cameras to be included in this pricing?	Yes. The cabling for the cameras is to be included.

Data Cabling for New May Howard Elementary School

Number: RFP 16-54

Posting Date: 1/26/2016

Addendum # 1

Closing Date: 02/10/16 @ 11:00 A.M.

Clarification:

- 1. The period of performance for this contract will begin with contract award and remain effective through June 2019.**
- 2. The Construction Manager at Risk (CMR) will require the successful contractor to have their personnel attend their regularly scheduled safety meetings.**

A copy of the pre-bid meeting attendance register is provided with Addendum #1.

*****All other terms and conditions of the RFP remain unchanged*****

END OF ADDENDUM NO. 1