

Data Cabling for New Jenkins High School (ERATE Eligible)

Number: RFP 20-46

Addendum # 3

The information contained in this document shall become an official part of the original document and shall be acknowledged as noted on the Proposal Certification Form (Form 2) of solicitation document in the space provided. Failure to acknowledge receipt of an addendum may result in a status of non-responsive. Firms are encouraged to review the contents of this document and to respond accordingly.

Addendum No. 3 is issued to answer the following question.

Question:	Answer:
1. How many cables are required to be installed to each of the areas that have a symbol (triangle) with no nomenclature?	If there is a triangle with no quantity by it, then automatically account for two (2) cables.

*****ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED*****

End of Addendum #3 to RFP 20-46 Data Cabling for New Jenkins High School (ERATE Eligible)